





Product Service

# CERTIFICATE

No. Z2 099333 0062 Rev. 04

## Model(s):

LR6-72-xxxM, (xxx=335 to 360 in step of 5)  
 LR6-60-xxxM, (xxx=280 to 300 in step of 5)  
 LR6-72PE-xxxM, (xxx=340 to 380 in step of 5)  
 LR6-60PE-xxxM, (xxx=285 to 315 in step of 5)  
 LR6-72BK-xxxM, (xxx=335 to 360 in step of 5)  
 LR6-60BK-xxxM, (xxx=280 to 300 in step of 5)  
 LR6-72PB-xxxM, (xxx=340 to 380 in step of 5)  
 LR6-60PB-xxxM, (xxx=285 to 315 in step of 5)  
 LR6-72HPB-xxxM, (xxx=360 to 385 in step of 5)  
 LR6-60HPB-xxxM, (xxx=300 to 320 in step of 5)  
 LR4-72HPB-xxxM, (xxx=405 to 425 in step of 5)  
 LR4-60HPB-xxxM, (xxx=335 to 365 in step of 5)  
 LR6-60HIB-xxxM, (xxx=300 to 320 in step of 5)  
 LR4-60HIB-xxxM, (xxx=335 to 365 in step of 5)  
 LR4-60ZPB-xxxM, (xxx=340 to 360 in step of 5)  
 LR4-60ZIB-xxxM, (xxx=340 to 360 in step of 5)  
 xxx is standing for rated output power at STC

## Parameters:

Fire Safety Class:	Class C according to UL790.
Safety Class:	Class II
Max. System Voltage:	1000V DC
Test Laboratory:	Yangzhou Opto-Electrical Products Testing Institute. No.10 West Kaifa Road, Yangzhou, 225009 Jiangsu, P.R.China.
Construction:	Framed, with Junction box, Cable and connector.

## Tested according to:

IEC 61215-1:2016  
 IEC 61215-1-1:2016  
 IEC 61215-2:2016  
 IEC 61730-1:2016  
 IEC 61730-2:2016  
 EN 61215-1:2016  
 EN 61215-1-1:2016  
 EN 61215-2:2017  
 EN IEC 61730-1:2018  
 EN IEC 61730-1:2018/AC:2018-06  
 EN IEC 61730-2:2018  
 EN IEC 61730-2:2018/AC:2018-06

## Production Facility(ies):

001192, 002875, 090968, 096558, 099605, 099606, 099626,  
 097323, 102892, 103410, 103841

TÜV SÜD TÜV SÜD TÜV SÜD TÜV SÜD TÜV SÜD TÜV SÜD TÜV SÜD TÜV SÜD TÜV SÜD TÜV SÜD TÜV SÜD TÜV SÜD TÜV SÜD TÜV SÜD TÜV SÜD  
 ZERTIFIKAT ◆ CERTIFICATE ◆ 認證證書 ◆ CERTIFICADO ◆ CERTIFICAT